

[Click here to go to UL's iQ™ for Appliance Wiring Materials Database](#)

UNDERWRITERS LABORATORIES

APPLIANCE WIRING MATERIAL

Subj.758

Section 1

Page 1230

Issued:1960-12-02

Revised:2009-03-28

Style 1230

Insulated Wire.

Rating 105 deg C, 600 Vac, Horizontal flame, 60 deg C wet,
 optional Oil Resistance 60 deg C.

Conductor 26 AWG - 9 AWG solid or stranded.

Insulation R/C QMTT2 PVC Insulation Compounds for use in Type TW,
 30 mils minimum average, 27 mils minimum at any point.

Standard Appliance Wiring Material UL 758.

Marking General.

Use Internal Wiring.