

[Click here to go to UL's iQ™ for Appliance Wiring Materials Database](#)

UNDERWRITERS LABORATORIES

APPLIANCE WIRING MATERIAL

Subj.758

Section 3

Page 3321

Issued:1977-05-25

Revised:2008-05-27

Style 3321

Insulated Wire

Rating 150 deg C, 600 Vac, 750 Vdc, Horizontal flame.

Conductor 30 AWG - 4/0 AWG solid or stranded round, tinned or bare copper.

Insulation XLPE

30-9 AWG conductor size	30 mils min average	27 mils minimum at any point
8-4 AWG	45 avg	40 min
2 AWG	60 avg	54 min
1-4/0 AWG	80 avg	72 min

Covering Optional-treated or untreated braid.

Standard Appliance Wiring Material UL 758.

Marking General.

Use Internal wiring of appliances.